

Just feel well

CNE 009 [ECODESIGN]

Cassette 600x600 mono & premium multi / DC Inverter











- → Cassette line available in capacity 2.5 kW.
- → Cooling & heating operation mode.
- → DC Inverter and sine wave compressor drive technology.
- → "I feel" function with precise room temperature control.



PRODUCT ADVANTAGES

- > Temperature control adjustment according to installation height.
- > Available with two sizes of panels 600x600 mm or 725x725 mm.
- > Compact design, only 219 mm unit net height.
- > Possibility to connect to alarm output, unit ON/OFF output, human presence detector and group control.
- > Fresh air supplied.
- > Heating only mode force option.



RC08W

[EC COMPLY Comply with ECO Design regulation





Just feel well

[INFORMATION REQUIREMENTS]

		AWAU-YB	DE009-H11	/ AWSI-CNE009-N11			
Function (indicate if present)				If function includes heating: Indicate the heating season the information relates to. Indicated values should relate to one heating season at a time. Include at least the heating season 'Average'.			
Cooling	T	Y		Average (mandatory)		Υ	
Heating		Υ		Warmer (if designated)		N	
				Colder (if designated)	if designated) N		
tem	symbol	value	unit	Item	symbol	value	unit
Design load				Seasonal efficiency			
Cooling	Pdesignc	2.5	kW	Cooling	SEER	5.70	-
Heating/Average	Pdesignh	2.5	kW	Heating/Average	SCOP(A)	4.00	-
Heating/Warmer	Pdesignh	-	kW	Heating/Warmer	SCOP(W)	-	-
Heating/Colder	Pdesignh	-	kW	Heating/Colder	SCOP(C)	-	-
Declared capacity (*) for cooling, at indoor temp	perature 27(19) °C	and outdoor	temperature	Declared energy efficiency ratio (*), at indoor to temperature Tj	emperature 27(19)	C and outdo	or
ī = 35 °C	Pdc	2.6	kW	Tj = 35 °C	EERd	4.4	_
Γj = 30 °C	Pdc	1.8	kW	Tj = 30 °C	EERd	6.0	_
Γj = 25 °C	Pdc	1.7	kW	Tj = 25 °C	EERd	7.6	_
Γj = 20 °C	Pdc	1.4	kW	Tj = 20 °C	EERd	8.7	_
Declared capacity (*) for heating/Average season				Declared coefficient of performance (*)/Average			20 °C and
emperature Tj	,			outdoor temperature Tj	,		
Γj = − 7 °C	Pdh	2.2	kW	Tj = − 7 °C	COPd	2.9	-
Гj = 2 °С	Pdh	1.4	kW	Tj = 2 °C	COPd	3.8	-
Гj = 7 °С	Pdh	1.3	kW	Tj = 7 °C	COPd	5.3	-
Гj = 12 °С	Pdh	1.5	kW	Tj = 12 °C	COPd	6.2	-
Γj = bivalent temperature	Pdh	2.2	kW	Tj = bivalent temperature	COPd	2.9	-
j = operating limit	Pdh	2.4	kW	Tj = operating limit	COPd	2.4	-
Declared capacity (*) for heating/Warmer seaso emperature Tj	n, at indoor tempe	erature 20 °C	and outdoor	Declared coefficient of performance (*)/Warme outdoor temperature Tj	er season, at indoor	temperature	20 °C and
Fi = 2 °C	Pdh	-	kW	Tj = 2 °C	COPd	-	-
Γj = 7 °C	Pdh	-	kW	Tj = 7 °C	COPd	-	-
Γj = 12 °C	Pdh	-	kW	Tj = 12 °C	COPd	-	-
Γj = bivalent temperature	Pdh	-	kW	Tj = bivalent temperature	COPd	-	-
i = operating limit	Pdh	-	kW	Tj = operating limit	COPd	-	-
Declared capacity (*) for heating/Colder season	, at indoor temper	ature 20 °C a	nd outdoor	Declared coefficient of performance (*)/Colder	season, at indoor	emperature :	20 °C and
emperature Tj	Dalla		LAM	outdoor temperature Tj	COD4		
Γj = −7 °C	Pdh	-	kW	Tj = - 7 °C	COPd		-
Γj = 2 °C	Pdh	-	kW	Tj = 2 °C	COPd	-	-
Γj = 7 °C	Pdh Pdh	-	kW	Tj = 7 °C	COPd COPd	-	<u> </u>
Γj = 12 °C	Pdh		kW	Tj = 12 °C Tj = bivalent temperature	COPd		-
Γj = bivalent temperature Γj = operating limit	Pdh		kW		COPd	-	-
Fj = - 15 °C	Pdh		kW	Tj = operating limit Tj = -15 °C	COPd		
Bivalent temperature	i dii	_	KVV	Operating limit temperature	001 0		
Heating/Average	Tbiv	-7	°C	Heating/Average	Tol	-15	°C
Heating/Warmer	Tbiv	-	°C	Heating/Warmer	Tol	-	°C
Heating/Colder	Tbiv	_	°C	Heating/Colder	Tol	_	°C
Power consumption of cycling	1517			Efficiency of cycling	101		
Cooling	Pcycc	_	kW	Cooling	EERcyc	_	_
Heating	Pcych		kW	Heating	COPcyc	-	_
Degradation co-efficient cooling (**)	Cdc	_	-	Degradation co-efficient heating (**)	Cdh	_	_
Electric power input in power modes		ive mode'		Seasonal electricity consumption			
Off mode	POFF	-	kW	Cooling	Q _{CE}	154	kWh/a
Standby mode	PSB	0.011	kW	Heating/Average	Q _{HE}	875	kWh/a
Thermostat-off mode	PTO	0.020	kW	Heating/Warmer	Q _{HE}	/	kWh/a
Crankcase heater mode	PCK	-	kW	Heating/Colder	Q _{HE}	/	kWh/a
Capacity control (indicate one of three	_			Other items	₩HE		
		N		Sound power level (indoor/outdoor)	LWA	49/61	dB(A)
ixed							. ~~ (/ 1/
Fixed Staged		N			GWP	1975	kaCO. ea
Fixed Staged /ariable		N Y		Global warming potential Rated air flow (indoor/outdoor)	GWP	1975 420/1780	kgCO ₂ eq

(*) For staged capacity units, two values divided by a slash ('/') will be declared in each box in the section 'Declared capacity of the unit' and 'declared EER/COP' of the unit. (**) If default Cd = 0,25 is chosen then (results from) cycling tests are not required. Otherwise either the heating or cooling cycling test value is required.

2