

ALL SEASONS KIT FOR DN 125 / 155 / 185 / 205 / 255 / 305
KIT "TOUTES SAISONS" POUR DN 125 / 155 / 185 / 205 / 255 / 305
BAUSATZ FÜR ALLE JAHRESZEITEN FÜR DN 125 / 155 / 185 / 205 / 255 / 305
KIT "TUTE LE STAGIONI" PER DN 125 / 155 / 185 / 205 / 255 / 305
KIT TODAS LAS ESTACIONES PARA DN 125 / 155 / 185 / 205 / 255 / 305



POWER SUPPLY MUST BE SWITCHED OFF BEFORE STARTING TO WORK IN THE ELECTRIC CONTROL BOX!

MISE HORS TENSION OBLIGATOIRE AVANT TOUTE INTERVENTION DANS LES BOITIERS ELECTRIQUES.

VOR JEDEM EINGRIFF AN DEN ANSCHLUSSKÄSTEN UNBEDINGT DAS GERÄT ABSCHALTEN!

PRIMA DI OGNI INTERVENTO SULLE CASSETTE ELETTRICHE ESCLUDERE TASSATIVAMENTE L'ALIMENTAZIONE !

PUESTA FUERA DE TENSION OBLIGATORIA ANTES DE CUALQUIER INTERVENCIÓN EN LAS CAJAS ELÉCTRICAS!



X 1



X 1



X 1

Cooling only model / Modèle froid seul / Nur Kühlung / Freddo soltanto / Sólo frío



X 1

Heatpump model / Modèle réversible / Wärmepump / Pompa di calore / Bomba de calor




X 1



X 1





1



2




3



4

MODEL 125 / MODÈLE 125 / MODELL 125 / MODELLO 125 / MODELO 125



Cooling only model / Modèle froid seul / Nur Kühlung / Freddo soltanto / Sólo frío


Insert terminals on existing DIN rail.

Insérer les bornes sur le rail Din existant.

Die Grenzen auf der bestehenden DIN-Schiene einfügen.

Inserire i terminali sulla barra Din esistente.

Insertar los terminales sobre el carril Estruendo existente.



Heatpump model / Modèle réversible / Wärmepump / Pompa di calore / Bomba de calor


Fix provided DIN rail.

Fixer le rail DIN fourni.

Die gelieferte DIN-Schiene festzulegen.

Per riparare guida fornita DIN.

Para fijar el estruendo proporcionado del carril.



Insert terminals and relay provided.

Insérer les bornes et le relais fournis.


Die gelieferten Grenzen und das Relais einfügen.

Inserisca i terminali ed il relè forniti.

Inserte los terminales y el relais proporcionados.

4

MODEL 155 / MODÈLE 155 / MODELL 155 / MODELLO 155 / MODELO 155



Cooling only model / Modèle froid seul / Nur Kühlung / Freddo soltanto / Sólo frío

Insert terminals on existing DIN rail.

Insérer les bornes sur le rail Din existant.

Die Grenzen auf der bestehenden DIN-Schiene einfügen.

Inserire i terminali sulla barra Din esistente.

Insertar los terminales sobre el carril Estruendo existente.

Heatpump model / Modèle réversible / Wärmepump / Pompa di calore / Bomba de calor


Fix provided DIN rail.

Fixer le rail DIN fourni.

Die gelieferte DIN-Schiene festzulegen.

Per riparare guida fornita DIN.

Para fijar el estruendo proporcionado del carril.



Insert terminals and relay provided.

Insérer les bornes et le relais fournis.


Die gelieferten Grenzen und das Relais einfügen.

Inserisca i terminali ed il relè forniti.

Inserte los terminales y el relais proporcionados.

4

MODEL 185 / MODÈLE 185 / MODELL 185 / MODELLO 185 / MODELO 185



Cooling only model / Modèle froid seul / Nur Kühlung / Freddo soltanto / Sólo frío


Insert terminals provided.

Insérer les bornes fournies.

Die gelieferten Grenzen einfügen.

Inserisca i terminali forniti.

Inserte los terminales proporcionados.



Heatpump model / Modèle réversible / Wärmepump / Pompa di calore / Bomba de calor

Insert terminals and relay provided.

Insérer les bornes et le relais fournis.


Die gelieferten Grenzen und das Relais einfügen.

Inserisca i terminali ed il relè forniti.

Inserte los terminales y el relais proporcionados.

4

MODEL 205-255-305 / MODÈLE 205-255-305 / MODELL 205-255-305 / MODELLO 205-255-305 / MODELO 205-255-305



Cooling only model / Modèle froid seul / Nur Kühlung / Freddo soltanto / Sólo frío

Insert terminals provided.

Insérer les bornes fournies.

Die gelieferten Grenzen einfügen.

Inserisca i terminali forniti.

Inserte los terminales proporcionados.



Heatpump model / Modèle réversible / Wärmepump / Pompa di calore / Bomba de calor

Insert terminals and relay provided.




Insérer les bornes et le relais fournis.

Die gelieferten Grenzen und das Relais einfügen.

Inserisca i terminali ed il relè forniti.

Inserte los terminales y el relais proporcionados.

6



7: ON